



Gujarat Water Supply & Sewerage Board,

"Jal Bhavan", Sector-10-A.

Opp. Air force Station,

Gandhinagar-382010. Ph. (079) 23251092

Fax-(079) 23240631/23225979

415
C

No. Mat. Cell/C/HDPE pipes/4172/ 915

Dt. 11-12-19

Sub: Supply of inferior quality HDPE pipes in Borisavar-Ghansiyamedha RWSS & SK-2 Regional (Shinawada-Dungarvada) Scheme

- Ref:**
- 1) GWSSB, Gandhinagar letter No. 161 dtd. 4-3-2014 & 109 dtd. 28-2-2017
 - 2) Chief Engineer, Zone-1/Vadodara letter No.2024 dtd. 18-4-2019 & 2210 dtd.3-5-2019
 - 3) This office letter no. Mat.Cell/C/HDPE pipe/382 dtd.15-5-2019
 - 4) Chief Engineer, Zone-2/Ahmedabad letter no. 2010 dtd. 10-5-2019
 - 5) Your letter No. PPPL/GWSSB-UCHCHHL/2019 dtd.20-5-2019

Preamble:

GWSSB came to know that HDPE pipes supplied by M/s. Purma Plast Pvt. Ltd., Bhivandi for Borisavar-Ghansiyamedha Regional water supply scheme have failed during testing & commissioning of the pipeline. On inquiring the matter it is came to know that lot No. & Batch No. on the pipes are overlapping & not matching with the lot No. & Batch No. printed on the pipes which were tested at factory site during pre-delivery inspection and hence it seems that pipes supplied by the agency are different pipes other than the pipes tested & passed during joint pre-delivery inspection carried out at plant. In this regards, Board had issued notice to M/s. Purma plast Pvt. Ltd., Bhivandi & asked to replace inferior quality pipes & to clarify that why punitive actions should not be initiated against this firm and why they shall not be removed from approved vendor list of GWSSB/ Blacklisted. In reply to this M/s. Purma Plast Pvt. Ltd., Bhivandi has denied to replace inferior quality pipes.


Meanwhile, Chief Engineer, Zone-2/Ahmedabad submitted report regarding HDPE pipes supplied by M/s. Purma Plast Pvt. Ltd., Bhivandi under Shinavada-Dungarvada Group under S.K.-2 Package have failed during testing & commissioning of the pipeline. It is also reported that agency M/s. Purma Plast haven't given any response for replacement of inferior quality pipes.

Due to supply of inferior quality pipes, both the projects haven't been completed in stipulated time frame & water supply to beneficiary villages could not be started. The projects affected badly by occurring huge financial burden in replacement of inferior quality pipeline and retesting & re-commissioning of pipeline.

Order:

Looking to the fraudulent practice committed by the agency in delivering the pipes to GWSSB and In view of failure of HDPE pipes supplied by M/s. Purma Plast Pvt. Ltd., Bhivandi during testing & commissioning of the Scheme, as per vendor selection policy of the Board, GWSSB hereby compel to order that,

Remove M/s. Purma Plast Pvt. Ltd., Bhivandi from approved vendor list of GWSSB and debarred for next three years from the date of issue of this order for bidding in the State in any of the tender invited by GWSSB/GWIL/WASMO/& supply of pipes.


Chief Engineer
Material Cell (C)
GWSSB, Gandhinagar

Copy submitted to:

- Hon. Chairman (W.S.), GWSSB, Gandhinagar for inf.
- Hon. Member Secretary, GWSSB, Gandhinagar for Inf.

Copy f.w. cs to:

- PA to Secretary (water supply), N.W.R.W.S. & Kalpsar Dept., 9th floor, Block No. 7, Sachivalaya, Gandhinagar for inf.
- PA to Principal Secretary (Narmada), N.W.R.W.S. & Kalpsar Dept., Gandhinagar for inf.
- PA to Secretary (water resources), N.W.R.W.S. & Kalpsar Dept., 2nd floor, Block No. 9, Sachivalaya, Gandhinagar for inf.
- PA to Additional Chief Secretary, Agriculture Dept., Gandhinagar for inf.
- PA to Additional Chief Secretary, Urban Development Dept., Gandhinagar for inf.
- PA to Additional Chief Secretary, Forest Dept., Gandhinagar for inf.
- PA to Additional Chief Secretary, Urban Development Dept., Gandhinagar for Inf.
- P.A. to Managing Director, SSNL, Gandhinagar for Inf.
- Commissioner, Municipality Administrator, GUDM, Gandhinagar
- Chief Engineer, Zone-I/Vadodara, II/Ahmedabad, III/Rajkot, IV/Kutch/Bhuj, V/Junagadh, VI/Surat, Urban Cell/Gandhinagar, Mech/Gandhinagar for inf.
- MD, GWIL, Gandhinagar for inf.
- CEO, WASMO, Gandhinagar for inf.
- Financial Controller, GWSSB, Gandhinagar for inf.
- Municipal Commissioner,
Ahmadabad/Vadodara/Rajkot/Surat/Bhavnagar/Junagadh/ Gandhinagar &
Jamnagar.
- SE, Vigilance Cell, GWSSB, Gandhinagar for inf.
- M/s. Purma Plast Pvt. Ltd., Bhivandi for inf.